



# ARRO Laboratory, Inc.

REVISED

Est. 1965

P.O. Box 686 Caton Farm Road  
Joliet, Illinois 60434

Phone: 815-727-5436  
FAX 815-740-3234

## Drinking Water Analysis

Batch 170331E

### Customer:

Company: Laraway Schools 70C

Address: 275 W Laraway Rd

City/State/Zip: Joliet, IL 60436

### P.O. Number:

Date Received 3/31/2017

Date Complete 4/11/2017

Sample ID 408163 Sample Description OFFICE 17C 1st Sample Date 3/31/2017 9:30:00 AM

Analyte	Concentration	Units	Analyst	Date	Method
Lead	22.76	µg/L	JS	04/07/17 0:00	200.5R4.2

Sample ID 408164 Sample Description OFFICE 17C 2nd Sample Date 3/30/2017 9:30:00 AM

Analyte	Concentration	Units	Analyst	Date	Method
Lead	2.88	µg/L	JS	04/07/17 0:00	200.5R4.2

Sample ID 408165 Sample Description STAFF 1 1st Sample Date 3/30/2017 9:40:00 AM

Analyte	Concentration	Units	Analyst	Date	Method
Lead	2.97	µg/L	JS	04/07/17 0:00	200.5R4.2

Sample ID 408166 Sample Description STAFF 1 2nd Sample Date 3/30/2017 9:40:00 AM

Analyte	Concentration	Units	Analyst	Date	Method
Lead	2.26	µg/L	JS	04/07/17 0:00	200.5R4.2

Sample ID 408167 Sample Description RM 2 1st Sample Date 3/30/2017 9:44:00 AM

Analyte	Concentration	Units	Analyst	Date	Method
Lead	3.91	µg/L	JS	04/07/17 0:00	200.5R4.2

Sample ID 408168 Sample Description RM 2 2nd Sample Date 3/30/2017 9:44:00 AM

Analyte	Concentration	Units	Analyst	Date	Method
Lead	2.76	µg/L	JS	04/07/17 0:00	200.5R4.2

Batch 170331E



# ARRO Laboratory, Inc.

Est. 1965

P.O. Box 686 Caton Farm Road  
Joliet, Illinois 60434

Phone: 815-727-5436

FAX 815-740-3234

**Sample ID** 408169      **Sample Description** RM 3 1st      **Sample Date** 3/30/2017 9:48:00 AM

Analyte	Concentration	Units	Analyst	Date	Method
Lead	3.42	µg/L	JS	04/07/17 0:00	200.5R4.2

**Sample ID** 408170      **Sample Description** RM 3 2nd      **Sample Date** 3/30/2017 9:48:00 AM

Analyte	Concentration	Units	Analyst	Date	Method
Lead	< 2.0	µg/L	JS	04/07/17 0:00	200.5R4.2

**Sample ID** 408171      **Sample Description** RM 4 1st      **Sample Date** 3/30/2017 9:52:00 AM

Analyte	Concentration	Units	Analyst	Date	Method
Lead	5.62	µg/L	JS	04/07/17 0:00	200.5R4.2

**Sample ID** 408172      **Sample Description** RM 4 2nd      **Sample Date** 3/30/2017 9:52:00 AM

Analyte	Concentration	Units	Analyst	Date	Method
Lead	< 2.0	µg/L	JS	04/07/17 0:00	200.5R4.2

**Sample ID** 408173      **Sample Description** RM 5 1st      **Sample Date** 3/30/2017 9:57:00 AM

Analyte	Concentration	Units	Analyst	Date	Method
Lead	3.69	µg/L	JS	04/07/17 0:00	200.5R4.2

**Sample ID** 408174      **Sample Description** RM 5 2nd      **Sample Date** 3/30/2017 9:57:00 AM

Analyte	Concentration	Units	Analyst	Date	Method
Lead	2.46	µg/L	JS	04/07/17 0:00	200.5R4.2

**Sample ID** 408175      **Sample Description** RM 6 1st      **Sample Date** 3/30/2017 10:03:00 A

Analyte	Concentration	Units	Analyst	Date	Method
---------	---------------	-------	---------	------	--------



# ARRO Laboratory, Inc.

Est. 1965

P.O. Box 686 Caton Farm Road  
Joliet, Illinois 60434

Phone: 815-727-5436  
FAX 815-740-3234

Lead 2.60 µg/L JS 04/07/17 0:00 200.5R4.2

**Sample ID** 408176 **Sample Description** RM 6 2nd **Sample Date** 3/30/2017 10:03:00 A

Analyte	Concentration	Units	Analyst	Date	Method
Lead	2.09	µg/L	JS	04/07/17 0:00	200.5R4.2

**Sample ID** 408177 **Sample Description** WATER FOUNTAIN SOUTH 1st **Sample Date** 3/30/2017 10:08:00 A

Analyte	Concentration	Units	Analyst	Date	Method
Lead	2.10	µg/L	JS	04/07/17 0:00	200.5R4.2

**Sample ID** 408178 **Sample Description** WATER FOUNTAIN SOUTH 2nd **Sample Date** 3/30/2017 10:08:00 A

Analyte	Concentration	Units	Analyst	Date	Method
Lead	< 2.0	µg/L	JS	04/07/17 0:00	200.5R4.2

**Sample ID** 408179 **Sample Description** WATER FOUNTAIN NORTH 1st **Sample Date** 3/30/2017 10:13:00 A

Analyte	Concentration	Units	Analyst	Date	Method
Lead	4.11	µg/L	JS	04/07/17 0:00	200.5R4.2

**Sample ID** 408180 **Sample Description** WATER FOUNTAIN NORTH 2nd **Sample Date** 3/30/2017 10:13:00 A

Analyte	Concentration	Units	Analyst	Date	Method
Lead	< 2.0	µg/L	JS	04/07/17 0:00	200.5R4.2

**Sample ID** 408181 **Sample Description** KITCHEN 1st **Sample Date** 3/30/2017 10:20:00 A

Analyte	Concentration	Units	Analyst	Date	Method
Lead	8.32	µg/L	JS	04/07/17 0:00	200.5R4.2



# ARRO Laboratory, Inc.

Est. 1965

P.O. Box 686 Caton Farm Road  
Joliet, Illinois 60434

Phone: 815-727-5436  
FAX 815-740-3234

**Sample ID** 408182      **Sample Description** KITCHEN 2nd      **Sample Date** 3/30/2017 10:20:00 A

Analyte	Concentration	Units	Analyst	Date	Method
Lead	2.14	µg/L	JS	04/07/17 0:00	200.5R4.2

**Sample ID** 408183      **Sample Description** RM 8 1st      **Sample Date** 3/30/2017 10:27:00 A

Analyte	Concentration	Units	Analyst	Date	Method
Lead	3.09	µg/L	JS	04/07/17 0:00	200.5R4.2

**Sample ID** 408184      **Sample Description** RM 8 2nd      **Sample Date** 3/30/2017 10:27:00 A

Analyte	Concentration	Units	Analyst	Date	Method
Lead	2.30	µg/L	JS	04/07/17 0:00	200.5R4.2

**Sample ID** 408185      **Sample Description** RM 9 1st      **Sample Date** 3/30/2017 10:35:00 A

Analyte	Concentration	Units	Analyst	Date	Method
Lead	2.35	µg/L	JS	04/07/17 0:00	200.5R4.2

**Sample ID** 408186      **Sample Description** RM 9 2nd      **Sample Date** 3/30/2017 10:35:00 A

Analyte	Concentration	Units	Analyst	Date	Method
Lead	< 2.0	µg/L	JS	04/07/17 0:00	200.5R4.2

**Sample ID** 408187      **Sample Description** RM 11 1st      **Sample Date** 3/30/2017 10:40:00 A

Analyte	Concentration	Units	Analyst	Date	Method
Lead	4.09	µg/L	JS	04/07/17 0:00	200.5R4.2

**Sample ID** 408188      **Sample Description** RM 11 2nd      **Sample Date** 3/30/2017 10:40:00 A

Analyte	Concentration	Units	Analyst	Date	Method
Lead	2.39	µg/L	JS	04/07/17 0:00	200.5R4.2



# ARRO Laboratory, Inc.

Est. 1965

P.O. Box 686 Caton Farm Road  
Joliet, Illinois 60434

Phone: 815-727-5436

FAX 815-740-3234

<b>Sample ID</b> 408189	<b>Sample Description</b> RM 13 1st	<b>Sample Date</b> 3/30/2017 10:45:00 A
----------------------------	--	--

Analyte	Concentration	Units	Analyst	Date	Method
Lead	6.75	µg/L	JS	04/07/17 0:00	200.5R4.2

<b>Sample ID</b> 408190	<b>Sample Description</b> RM 13 2nd	<b>Sample Date</b> 3/30/2017 10:45:00 A
----------------------------	--	--

Analyte	Concentration	Units	Analyst	Date	Method
Lead	2.21	µg/L	JS	04/07/17 0:00	200.5R4.2

<b>Sample ID</b> 408191	<b>Sample Description</b> RM 14 1st	<b>Sample Date</b> 3/30/2017 10:50:00 A
----------------------------	--	--

Analyte	Concentration	Units	Analyst	Date	Method
Lead	9.00	µg/L	JS	04/07/17 0:00	200.5R4.2

<b>Sample ID</b> 408192	<b>Sample Description</b> RM 14 2nd	<b>Sample Date</b> 3/30/2017 10:50:00 A
----------------------------	--	--

Analyte	Concentration	Units	Analyst	Date	Method
Lead	2.17	µg/L	JS	04/07/17 0:00	200.5R4.2

I CERTIFY THAT THE RESULTS RELATE ONLY TO THE SAMPLES AND I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE, COMPLETE AND ACCURATE. I ALSO CERTIFY THAT THE TEST RESULTS MEET ALL THE REQUIREMENTS OF NELAC. Illinois EPA Certification Number 100280.

4/19/2017

APPROVED BY

*Joan Serdar*  
Joan Serdar, Director

Comments:

OAK VALLY ELEMENTARY SCHOOL WATER NOT USED AFTER 8:00PM ON 3/29/17